

**Agenda**  
**Mechanical Board of Appeals and Examiners**  
**Building Services Conference Room**  
**May 13, 2009, 12 noon**

**Approval of Minutes of Last Meeting**

**New Business**

1. **Appeal No. 4-2009** Thomas Stritecky of Waterbury Heating and Cooling, inc. will request that the Board provide clarifications of Section 504.6, Domestic clothes dryer ducts of the 2006 IMC. This section requires the ducts shall be constructed of metal and shall have a smooth interior finish; the duct shall be minimum nominal 4" diameter. Mr. Stritecky wants to use galvanized spiral piping.

**Adjournment**

**Accessibility.** Upon request, accommodations for this hearing will be provided for persons with disabilities. Please contact the Planning and Building Services Department office at 367-8670, 48 hours in advance.

**For questions concerning this hearing, please call (605) 367-8670 for assistance.**