

**Minutes
Mechanical Board of Appeals and Examiners
Building Services Conference Room
Wednesday, March 11, 2009 12 noon**

Members Present

Frank Hughes, Mark Schempp, Mark deWit, Mark Lamb

Members Absent

Jim Phelps

Guests Present

Gary Klarenbeek, Steve Robertson, Ron Bell, Paul Van Bockern, Dan Hauge, Dave Weber, David Krier, Mike Thompson

Approval of Minutes of Last Meeting

A motion was made by Mr. deWit and a second was made by Mr. Schempp to approve the minutes of February 11, 2009 with two changes. Yeses, 4. Noes, 0.

New Business

1. The file was opened for Appeal No.2-2009. Dan Hauge of Institutions Services inc. requested that the board allow the use of a Wittco model 1300 low temperature cook and hold oven without an exhaust hood.

A motion was made by Mr. deWit and a second was made by Mr. Lamb to approve the use of the Wittco 1300 without an exhaust hood.

Yeses, 4. Noes, 0.

2. The file was opened for Appeal No.3-2009. David Krier of Krier and Blain inc. requested that the board review section 708 of the 2006 IMC and section 304.11 of 2006 IFGC. In question is the location of the "high" combustion air opening.

A motion was made by Mr. Hughes and a second was made by Mr. deWit to deny the appeal and require the opening 12" from the top of the assembly.

Yeses, 4. Noes, 0.

***An audio tape of the meeting will be available at the City of Sioux Falls.**

Adjournment

A motion was made by Mr. Hughes and a second was made by Mr. deWit to adjourn the meeting at 1:40 PM. Yeses, 4. Noes, 0.

Michael P Denny

Secretary