

Lot 1

tag No#	KVA	Manufacturer	Trans. S/N	3 Phase or 1 Phase	secondary voltage	Pole mount	Pad mount	PCB testing lab	PCB test	Test Result parts per million	Comments
1	75	westinghouse	76D214117	3	120/240		x	T&R	2432NC	LESS THAN 2 PPM	from well 25
2	25	B&B	808011	1	240/120		X		NON pcb ON Name plate	NONE	NELSON PARK
3	7.5	allis chalmers	1771689	1	2400 120/240	x		T&R	2433NC	3 PPM	well 13
4	7.5	allis chalmers	1771690	1	2400 120/240	x		T&R	2434NC	2 PPM	well 13
5	7.5	allis chalmers	1771684	1	2400 120/240	x		T&R	2435NC	2 PPM	well 13
6	75	HOWARD	12236-0786	3	13802		X		2436NC	LESS THAN 2 PPM	6 PACK WELL
7	25	westinghouse	74AH17627	1	120 / 240	X					4TH ST. TRANS CLOSURE
8	100	westinghouse	74AE11892	1	240 / 480	X			2437NC	LESS THAN 2 PPM	4TH ST. TRANS CLOSURE
9	50	Jerrys Electric	42895-2	1	2		x		2438NC	LESS THAN 2 PPM	w. 26th and I-29
10	15	genral electric	M237561 YFNB	1	120 / 240	X		NATIONAL CHEM LAB	OE0052680	NONE	
11	15	T&R	83180	1	120 / 240	X			2439NC	LESS THAN 2 PPM	
12	25	ERMCO	24H587510	1	120 / 240		X		NON pcb ON Name plate	NONE	
13	37.5	Jerrys Electric	71889-2	1	120 / 240	x			Listed on name plate	LESS THAN 1 PPM on Name Plate	Tansclosure Hanger Lane