

Tag Number	KVA	Manufacturer	Trans. S/N	3 Phase or 1 Phase	secondary voltage	Pole mount	Pad mount	PCB testing lab	PCB test	Test Result parts per million	Comments
1	25	Genral Electric	M533030Y FPA	1	120 / 240	X		Preventive Chemical Behavior	7037	4	RUST
2	25	WESTINGHOUSE	74AK23426	1	240 / 480	X		T&R	57830	<2	"Lightning"
3	25	Genral Electric	m219463yena	1	120 / 240	X		T&R	3295	<2	Might be good need to check
4	25	GE	G221119-65Y	1	120/240	x		T&R	9036AB	<2	Secondary bussing burned up non usable
5	25	Standard	E28793	1	120 / 240	X		NON	FACTORY STICKER		Bad secondary winding
6	750	GE	319100TGPA	3	480/277		X	T&R	1850	9	RUSTED BOTTOM, NOT TANK
7	10	GE	M543337YFPA	1	120/240	X		JACO Anal.	4044783	0	OKAY
8	OCR	MCGRAW-EDISON	3700	3	Recloser			T&R	1381BD	<2	OKAY
9	KVAC 50	WESTINGHOUSE	79044549		CAPACITOR	X		cant test	N/A	N/A	6TH AND MABLE PRIMARY POLE- ACCIDENT, Good condition
10	KVAC 50	WESTINGHOUSE	79044548		CAPACITOR	X		cant test	N/A	N/A	6TH AND MABLE PRIMARY POLE- ACCIDENT, Good condition
11	KVAC 50	GE	E015192		CAPACITOR	X		cant test	N/A	N/A	6TH AND MABLE PRIMARY POLE- ACCIDENT, Good condition
12		WESTINGHOUSE	64E464CS		Oil switch/breaker	X		cant test	N/A	N/A	6TH AND MABLE PRIMARY POLE- ACCIDENT, Good condition
13		WESTINGHOUSE	64E450CS		Oil switch/breaker	X		cant test	N/A	N/A	6TH AND MABLE PRIMARY POLE- ACCIDENT, Good condition
14		WESTINGHOUSE	64E562CS		Oil switch/breaker	X		cant test	N/A	N/A	6TH AND MABLE PRIMARY POLE- ACCIDENT, Good condition
15	50	HOWARD	1036290118	1	120 / 240	X		NON	nameplate	N/A	DENTED CAN FROM ACCIDENT
16	50	B&B	611985	1	120 / 240	X		NON	nameplate	N/A	LIGHTNING DAMAGE
17	37.5	kuhlman	4077580586	1	120 / 240	x		N/A	nameplate	<1	Lightning damage
19	50	ST	E-31302	1	240 / 480	X		T&R	1749UU	<2	surface rust
20	50	GE	M212030JENA	1	120 / 240	X		T&R	1749UU	<2	surface rust
21	25	Electric Research	24H587510	1	120 / 240	X			NAMEPLATE	<1	surface rust
22	200	MCGRAW-EDISON	6630	3	Recloser		X	T&R	710611	<2	OKAY
23		WESTINGHOUSE	64E523CS	±	Oil switch/breaker	X		cant test	N/A	N/A	OKAY
24		WESTINGHOUSE	64E465CS	±	Oil switch/breaker	X		cant test	N/A	N/A	OKAY
25		WESTINGHOUSE	64E471CS	±	Oil switch/breaker	X		cant test	N/A	N/A	OKAY
26	50	B&B	8149615	1	120 / 240		X	NON	nameplate	N/A	Damaged door and rusty
28	25	B&B	6099917	1	120 / 240		X	NON	nameplate	N/A	Rusted and Leaking
29	37.5	kuhlman	4077580786	1	120 / 240	X		NON	nameplate		damaged can/ Accident
30	225	HOWARD	2169182893	3	120 /208		X	NON	nameplate		Rusted and Leaking
31	75	WESTINGHOUSE	A81E760729	3	277 / 480		X	T&R	1849	<2	DAMAGED FROM FAULT
32	167	ERMCO	26MI381000	1	120	X		NON	NAMEPLATE	N/A	RUSTY
33	167	WESTINGHOUSE	74AJ8806	1	120	X		T&R	1498C	<1	RUSTY
34	167	MCGRAW-EDISON	73ZH626001	1	120	X		T&R	1496C	<1	RUSTY
35	250	T&R	77166	1	277 / 480	X		T&R	718CC	<2	RUSTY
36	250	GE	L479362PFMA	1	277 / 480	X		T&R	1533C	<1	RUSTY
37	250	GE	L479363PFMA	1	277 / 480	X		T&R	1532C	<1	RUSTY