

Addendum No. 1

RFP 18-0001

Addendum and Answers to Questions

- 1. Do you want a concrete sub-base or a compacted stone sub-base for the poured in place rubber?**

Concrete.

- 2. At Whittier Park, you are showing a cross drawn in red on Page 37. What's the plan here?**

The areas in red are all areas that need concrete replaced or added.

- 3. The RFP says to include wear mats under the swings, but you do not call out any new swing sets?**

There are no swings requested in this RFP. We are planning on removing the swing sets and replacing them with a stand-alone piece.