

10/11/18

City of Sioux Falls

Addendum No. 1

Request 18-0153

RFP for Audio System Upgrade for the Mary Sommervold Hall at the Washington Pavilion

Please make the following changes or additions to the scope of work listed in the RFP:

1. Electrician for electrical work shall be included in your price proposal.
2. Labor rate for the rigger will \$25.00 per hour and shall be included in your price proposal.
3. Firms shall submit 3D modeling of audio dispersion with their response.
4. New audio system must be compatible and controlled by the existing BSS system. Firms shall state in their response how their proposed system will interface with the existing system.
5. Contractor is allowed to drill holes in the walls to run new conduit to shorten speaker wire runs. The only conduit requirement is to pass through the brick wall to the amp room to the concert hall. The contractor will have the choice to use existing conduit or pass through installation. Please note in the RFP response if this is the installation method chosen for the installation of the new audio system. Installation of new conduit shall be included in the price proposal.
6. Building drawings in PDF format have been downloaded to the City website and are available for download at <http://siouxfalls.org/business/rfq/2018/09/rfp-18-0153>
7. The BSS files are available upon request. Please contact via email at Dale Pope dpope@washingtonpavilion.org
8. Subway grating load ratings will be provided at a later date.

Sign this form and include with your RFP response.

Signature

Company

Date

