

10/19/18

City of Sioux Falls

Addendum No. 3

Request 18-0153

Audio System Upgrade for the Mary Sommervold Hall at the Washington Pavilion of Arts and Science.

Answers to questions received:

1. As an alternate to a passive loudspeaker system with amplifiers in the racks...can we get an alternate approval to provide an active system with amplifiers in the loudspeakers?

Answer: This solution is not approved.

2. Would we be approved for 2 loudspeaker points rather than 3.if we're able to achieve the audio dispersion/coverage with only 2 locations (lower & middle catwalks)?

Answer: This design is not approved. Based on past experience there will be difficulty covering all three zones with just two points. We need to have control over all three zones independently.

3. I would like to submit PreSonus StudioLive 32 Series 3 mixers - <https://www.presonus.com/products/StudioLive-32> - as an alternate to the Digico S21 mixer.

Answer: The PreSonus Studio Live 32 Series 3 mixer alternate is not approved.

Sign this form and include with your proposal response.

Signature

Company

Date