

**Agenda  
Board of Appeals  
City Council Chambers  
Tuesday, March 8th, 2011, 8 a.m.**

**Approval of Minutes of Last Meeting**

**New Business**

- 1. Appeal 1-2011.** Elton Byre owns an apartment at 219 S. Menlo Avenue. The building's fire alarm system was disabled by a fire located inside the fire alarm panel. It is the Fire Departments policy to require that where a fire alarm system is upgraded or replaced, minimum audibility provisions within the sleeping rooms are required to be at a nationally recognized audability level, 15 dba above ambient for existing construction or, with new construction 75 dba total, in order to wake a sleeping occupant. Mr. Byre will request that the Board accept the replacement of the fire alarm panel back into a working condition without any additional modifications to any other portion of the fire alarm system.

**Adjournment**

**Accessibility.** Upon request, accommodations for this hearing will be provided for persons with disabilities. Please contact the Planning and Building Services Department office at 367-8670, 48 hours in advance.

**For questions concerning this hearing, please call (605) 367-8670 for assistance.**