

Agenda
Mechanical Board of Appeals and Examiners
Building Services Conference Room
March 11, 2009, 12 noon

Approval of Minutes of Last Meeting

New Business

1. **Appeal No. 2-2009** Dan Hauge of Institutions Services inc. will request that the Board provide clarifications of Section 507.2 Where commercial kitchen hoods are required of the 2006 IMC. This section requires a Type I or Type II hood over all commercial cooking appliances. Mr. Hauge is asking the board to rule on a Wittco model 1300 low temperature cook and hold oven.
2. **Appeal No. 3-2009** David Krier of Krier Blaine Heating and Air Conditioning will request that the Board review the provision found in Item 6 of Section 708 Combustion Air Ducts. IMC, which does not allow a common duct to serve as the required upper and lower combustion air openings. At Dean Foods located at 1200 W. Russell Street, the upper and lower combustion air ducts are separated to the termination of a common exterior opening. Staff interprets that that the high and low ducts providing the combustion air are required to be completely separated and cannot terminate at the same exterior opening.

Adjournment

Accessibility. Upon request, accommodations for this hearing will be provided for persons with disabilities. Please contact the Planning and Building Services Department office at 367-8670, 48 hours in advance.

For questions concerning this hearing, please call (605) 367-8670 for assistance.