

**Agenda**  
**Mechanical Board of Appeals and Examiners**  
**Building Services Conference Room**  
**August 12, 2009, 12 noon**

**Approval of Minutes of Last Meeting**

**New Business**

1. Appeal No. 5-2009 Norm deWit of Associated Consulting Engineering, inc. will request that the Board provide clarifications of Section 514 of the 2006 IMC, Energy Recovery Ventilation Systems. This section does not allow for an Energy Recovery Ventilator to exhaust Type II hoods. Mr. deWit wants to replace an existing ERV and add an additional Type II hood the new ERV.
2. Review the 2009 IMC, IFGC, IRC codes and city ordinance.

**Adjournment**

**Accessibility.** Upon request, accommodations for this hearing will be provided for persons with disabilities. Please contact the Planning and Building Services Department office at 367-8670, 48 hours in advance.

**For questions concerning this hearing, please call (605) 367-8670 for assistance.**