

**Agenda**  
**Mechanical Board of Appeals and Examiners**  
**Building Services Conference Room**  
**Wednesday, December 8, 2010, 12 noon**

**New Business**

**Appeal No. 1-2010.** John P. Engelhardt of Architectural Guild LLC, will request the board eliminate the installation of a fire suppression as required by section 510.7 *suppression required* of the 2009 IMC. Mr. Engelhardt is stating that diesel fuel is the hazard and not gasoline at Wheelco Brake located at 4904 W. 12<sup>th</sup> street.

**Accessibility.** Upon request, accommodations for this hearing will be provided for persons with disabilities. Please contact the Planning and Building Services Department office at 367-8670, 48 hours in advance.

**For questions concerning this hearing, please call (605) 367-8670 for assistance.**