

**Agenda**  
**Mechanical Board of Appeals and Examiners**  
**Building Services Conference Room**  
**February 9, 2011, 12 noon**

**Approval of Minutes of Last Meeting**

**Unfinished Business**

1. None

**New Business**

1. Appeal No. 1-2011. Preston Mettler from Mettler Construction will request the board review and allow the use of a Venmar 2.6 HRV to be used to ventilate bathrooms in a single family dwelling. The defrost system on the Venmar will allow the “stale air” from the bathrooms to be exhausted back into the house. The code does not allow for the recirculation of air from a bathroom or toilet room.  
**2009 IRC Section M1507.2 Recirculation of air.** Exhaust air from bathrooms and toilet rooms shall not be recirculated within a residence or to another *dwelling unit* and shall be exhausted directly to the outdoors. Exhaust air from bathrooms and toilet rooms shall not discharge into an *attic*, crawl space or other areas inside the building.

**Adjournment**

**Accessibility.** Upon request, accommodations for this hearing will be provided for persons with disabilities. Please contact the Planning and Building Services Department office at 367-8670, 48 hours in advance.

**For questions concerning this hearing, please call (605) 367-8670 for assistance.**