

**Minutes**  
**Mechanical Board of Appeals and Examiners**  
**Building Services Conference Room**  
**April 11, 2012, 12 noon**

**Members Present**

Ryan Van Der Bill, Mark Weber, Jack Zimmer, Greg Bertsch and Mark Lamb

**Members Absent**

None

**Guests Present**

Steve Robertson and Mark Schempp

**Approval of Minutes of Last Meeting**

A motion was made by Mr. Zimmer and a second was made by Mr. Lamb to approve the minutes of March 12, 2012. Yeses, 5. Noes, 0.

**New Business**

1. The file was opened for Appeal No. 2-2012. Mark Schempp representing Schempp Heating and Air is requesting relief from section G2428.2.7 of the 2009 IFGC. Mr. Schempp presented the board with a flexible chimney liner manufactured by Tru-Flex Metal Hose LLC and a shop made coupling to attach the listed liner to the listed b-vent venting system. Mr. Schempp also presented the board with a UL listed adaptor manufactured by the Selkirk Corporation along with a letter from Selkirk. The adaptor from Selkirk is a listed product for the Selkirk branded Flexi-Liner to any listed B-vent. This adaptor does not have a UL listing for the Tru-Flex Metal Hose liner system. Mr. Robertson and Mr. Denny advised the board on the importance of the UL listing for the piping as well as the connection.

A motion was made by Mr. Lamb and a second was made by Mr. Zimmer to approve the Selkirk adaptor per letter indicating a listed flexible liner as spelled out in the letter from Selkirk to be connected to any type B vent chimney. Yeses, 3 (Mr. Zimmer, Mr. Lamb and Mr. Van Der Bill). Noes, 2 (Mr. Weber and Mr. Bertsch).

**Adjournment**

A motion was made by Mr. Weber and a second was made by Mr. Van Der Bell to adjourn the meeting at 1:10 p.m. Yeses, 5. Noes, 0.

Mike Denny  
Secretary

