

**Agenda**  
**Mechanical Board of Appeals and Examiners**  
**Building Services Conference Room**  
**Wednesday, October 14, 12 noon**

**Approval of minutes of last meeting**

**Unfinished business**

None

**New business**

1. Election of new officers
2. **Appeal BOA-ML-003369-2015.** Omega Quant and Tony Lee are seeking relief from IMC Section 501.3.1 Location of exhaust outlets, subsection 2 other product-conveying outlets: 10 feet from property lines and from IBC section 705.8.1 Allowable area of openings, openings in exterior walls 0-3 feet from property lines openings are not permitted. Fume hood exhaust has been installed exiting the rear of the building, which is 2 ½ feet from the property line line.

**Accessibility.** Upon request, accommodations for this hearing will be provided for persons with disabilities. Please contact the Planning and Building Services Department office at 367-8670, 48 hours in advance.

**For questions concerning this hearing, please call (605) 367-8670 for assistance.**